### Mock Document 2 — Equipment Manual (AHU-04)

File name: AHU-04 Equipment Manual.pdf (mock)

River Valley Medical Center — Facilities Engineering

**Equipment Manual Asset ID:** AHU-04

**Location:** East Wing Surgical Pavilion — Mechanical Penthouse

Manufacturer: AeroTherm Systems, Inc. (mock)

Model Number: ATX-4200 Serial Number: 04-2020-1738 Date Installed: March 2020

#### **Table of Contents**

1. General Description

- 2. Technical Specifications
- 3. Installation Overview
- 4. Operating Instructions
- 5. Maintenance Procedures
- 6. Troubleshooting Guide
- 7. Spare Parts List
- 8. Appendices (Wiring Diagram, Maintenance Logs, Warranty Statement)

## 1. General Description

Air Handling Unit AHU-04 serves the East Wing Surgical Pavilion including Operating Rooms 1–6, PACU, and associated sterile corridors. The system provides HEPA-filtered, temperature- and humidity-controlled air in compliance with ASHRAE 170 and applicable codes.

# 2. Technical Specifications (mock values)

• Airflow Capacity: 24,000 CFM (nominal)

• Static Pressure: 4.2 in. w.c.

• Cooling Coil: Chilled water, 6-row, 72 sq. ft.

• **Heating Coil:** Steam, 2-row

Filters:

- o Pre-filters: MERV 8, 24" x 24" x 2"
- o Final filters: HEPA, 99.97% efficiency, 24" x 24" x 12"
- **Fans:** Twin centrifugal, belt-driven
- Motor: 50 HP, 480V, 3-phase, 60Hz
- **Drive:** Belt drive with adjustable sheaves
- Controls: BACnet-enabled DDC controller
- Humidification: Steam grid injector, 60 lbs/hr capacity
- Sound Attenuators: Factory-installed

#### 3. Installation Overview

- Mounted on reinforced structural steel frame.
- Vibration isolators installed at base.
- Connected to hospital chilled water and steam distribution mains.
- Access provided via hinged panels and service platform.

# 4. Operating Instructions

- 1. Verify control system is powered and online.
- 2. Confirm setpoints: OR temperature 68°F, relative humidity 50% ±5%.
- 3. Start fan motors via BAS interface; confirm status lights green.
- 4. Monitor supply air temperature and humidity sensors.
- 5. Alarm conditions (filter DP high, coil freeze, fan fail) will annunciate to BAS.

#### 5. Maintenance Procedures

- Daily: Visual inspection of control panel indicators, BAS trending.
- Monthly:
  - o Inspect and record filter DP; replace if >2.0 in. w.c.
  - Inspect belts for wear and tension.
  - Check bearing lubrication.

# Quarterly:

- Perform full fan alignment and vibration analysis.
- Inspect coils; clean if pressure drop increases.
- Test humidifier steam grid function.

#### Annually:

- o Replace all pre-filters and HEPA filters.
- Drain and clean condensate pans; disinfect.
- Verify control sequences; recalibrate sensors.

# 6. Troubleshooting Guide (sample)

- **Symptom:** Excessive noise at startup.
  - o Possible Causes: Loose belt, worn bearings, misalignment.
  - o Corrective Action: Inspect belts and bearings; re-tension or replace.
- **Symptom:** High humidity in OR.
  - o Possible Causes: Steam injector malfunction, BAS sequence error.
  - Corrective Action: Inspect steam supply valve and BAS logic.
- **Symptom:** Filter DP alarm.
  - o Possible Causes: Clogged filters.
  - o Corrective Action: Replace filters, reset alarm.

# 7. Spare Parts List (selected)

- Fan Belts: BX-74, Qty: 2
- Bearing Kit: Part #BR-2045
- Pre-Filters: MERV 8, 24"x24"x2", Box of 12
- HEPA Filters: 24"x24"x12", Box of 6
- Motor: 50 HP replacement kit
- Actuator: Smoke damper actuator, BACnet compatible

# 8. Appendices

- Appendix A: Electrical Wiring Diagram (mock placeholder)
- Appendix B: Sample Maintenance Log Sheets (fillable)
- Appendix C: Manufacturer Warranty Statement (5 years parts, 1 year labor mock)

#### **End of Equipment Manual (AHU-04)**

**Document notes:** These two files were created as high-fidelity mock collateral for DEMO 2 of the MOSHE workshop. They provide realistic technician notes (plain text) and a robust equipment manual (PDF-style layout) suitable for uploading into AI systems during engineering demos. If ilecite turn 1 file 0